


Specifications of Desiccant Dryer
Faisalabad Institute of Cardiology, Faisalabad

Item Description	Qty
<p>AIR DRYER</p> <ul style="list-style-type: none">o Desiccant type, Duplex.o Dew Point range between -40 to -80°Co Dew point monitoring on LCD Panelo Capacity suitable according to the compressor output.o Including oil water separator.o Capacity: 190 m³/h or more. <p>FILTRATION SYSTEM</p> <ul style="list-style-type: none">o Clean Medical Grade Air supply in accordance with the requirements of HTM/ISO standards.o Consisting of Pre-filter / humidity, Oil free and sterile/bacteria filter.o Mounted with shut-off valves on an assembly panel.o Parallel Connections of the filters. This will make it possible to exchange filter without interrupting the air supply.o Flow / filtering rate according to the compressed air output.	01 No



Medical Superintendent
Faisalabad Institute of Cardiology,
Faisalabad.