

**MINUTES OF GRIEVANCE COMMITTEE MEETING
FAISALABAD INSTITUTE OF CARDIOLOGY, FAISALABAD**

A meeting of Grievance Committee for M & R Items for F. Y. 2020-21 was held on 22.12.2020 at 11:00AM in the Office of the Medical Superintendent, Faisalabad Institute of Cardiology, Faisalabad.



**M & R ITEMS
(ELECTRICAL)**

1. M/s I CACHE

Item #	Item Name	TAC Observations	GC Observation	Remarks
9	Euro Socket, 2-Pin, 16 Amp, Schneider	Not as per requirement	Not as per requirement Not compatible with existing system	TEC decision upheld
40,49 and 61	MCB Single Pole, 20 Amp, 10 KA, 230-400Amp, Schneider	Not as per requirement	Not as per requirement Not compatible with existing system	TEC decision upheld

2. M/s IHE





Item #	Item Name	TAC Observations	GC Observation	Remarks
3	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 3/0.029" single core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
4	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 7/0.029" single core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
5	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 3/0.029" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
6	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 7/0.044" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld


7	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 7/0.052" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
56	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 3/0.029" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld

3. M/s SMC

Item #	Item Name	TAC Observations	GC Observation	Remarks
3	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 3/0.029" single core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
4	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 7/0.029" single core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
5	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 3/0.029" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
6	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 7/0.044" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
7	PVC INSULATED PVC SHEATHED COPPER CONDUCTOR 7/0.052" two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld
34	Phase monitor relay 3-Phase 440V DIN Rail Mounting, Made in EU/Japan	Country of Origin not as required	The firm quoted brand is Turkish instead of EU/Japan	TEC decision upheld
49	MCB Single core 6Amp -10KA 230-400V Made in Japan	Country of Origin not as required	The firm quoted brand is Turkish instead of EU/Japan	TEC decision upheld
56	PVC Insulated PVC Sheathed copper conductor wire 3/0.29 two core	C & W approved letter not attached.	Provided "C & W approved letter" is expired.	TEC decision upheld

61	MCB Single pole 10Amp -10KA 230-400V Made in EU/Japan	Country of Origin not as required	Not compatible with the existing system End user reservation	TEC decision upheld
74	Power capacitor 50KVAR, 3-Phase 440-550V, 50Hz, Nokian Finland/equivalent	No past experience	No past experience of quoted item Not compatible with the existing system End user reservation	TEC decision upheld
75	Power capacitor 25KVAR, 3-Phase 440-550V, 50Hz, Nokian Finland/equivalent	No past experience	No past experience of quoted item Not compatible with the existing system End user reservation	TEC decision upheld

73	Mobil Oil Caltex Delo Gold 15W/40 (Equivalent)	Not according to required specification	The quoted product is not equivalent to required specification	TEC decision upheld
----	--	---	--	---------------------




Mrs. Iqra Munir,
Pharmacist,
FIC, Faisalabad.
(Copt. Member)



Ms. Aisha Sultana,
Pharmacist,
FIC, Faisalabad.
(Member)



Engr. Sharaz Ali,
Bio Medical Engineer,
FIC, Faisalabad.
(Member)



Dr. Shahbaz Ahmed,
Associate Prof. of Cardiac Surgery,
FIC, Faisalabad.
(Member)



Dr. Shahid Abbas,
Associate Prof. of Cardiology,
FIC, Faisalabad.
(Member)



Dr. Zafar Abbas Khan,
Medical Superintendent,
FIC, Faisalabad.
(Chairman)