Technical Specification of I.T Equipment Faisalabad Institute of Cardiology, Faisalabad.

.#	ITEM	DESCRIPTION
1	Processor	Intel Core i5 - 8400 8th generation processor (9M Chache) 2.80 GHz, 6 Core
	Mother Board	Intel original Compatible Motherboard
	Memory	4GB DDR4 -2666 RAM Upgradable to 32GB
	Hard Disk Drive	1 TB 7200 RPM Hard Disk
	Super Drive Internal	CD+/-RW and 8X DVD RW 16X DVD R or higher, compatible with Microsoft Windows Vista/7/8/8.1/10/2012
	Display Card/Sound Card	Built-in Video Graphics Display and Sound Card
	Network Adapter	Built-in 10/100/1000 base-T Gigabit Ethernet card (Microsoft Windows 2000/XP/2003/Vista/ 7/8Wake on LAN (WOL) support
	LED	19.5" inch LED Monitor Widescreen Flat Panel Display Monitor, Low Radiation 1024 x 768 Resolution supportive.
	Mouse & Key	Standard Keyboard and 2.0 USB 2-Buttons Optical Mouse with Scroll.
	Casing	Manufacturer Standard casing with standard Power Supply (Form Factor Tower)
OTE	E: 1 Years Parts	and Labor warranty for all components on site
2	Operating System	Microsoft Windows 10 Professional Media Kit and licenses 64 Bit

S.#	ITEM	DESCRIPTION	QTY
3	LaserJet Network Printer 40PPM	Print speed black: Normal Up to 40 ppm Print Resolution 1200 x 600 dpi, HP Fast Res 1200 dpi Processor speed 1200 MHz or higher Memory, standard 128 MB Duty cycle (monthly, A4) Up to 80,000 pages Recommended Monthly Pages: 750 To 40 00 Display control panel, Button LED Connectivity: Hi-Speed USB 2.0, Network ready Toner Refillable, Parts should be available in the market. 01 Year Parts and Labor warranty for all components on site	10
4	LaserJet Network Printer 28PPM	Print speed black: Normal Up to 28 ppm Print Resolution 1200 x 1200 dpi, HP Fast Res 1200 dpi Processor speed 800 MHz or higher Memory, standard 256 MB Duty cycle (monthly, A4) Up to 5000 pages or higher Connectivity: Hi-Speed USB 2.0, Toner Refillable, Parts should be available in the market. 01 Year Parts and Labor warranty for all components on site	10

Medical Superintendent
Faisalabad Institute of Cardiology,
Faisalabad.