MINUTES OF THE TECHNICAL EVALUATION COMMITTEE MEETING HELD ON 28/05/2021 AT 10 AM IN THE CONFERENCE ROOM OF F.I.C FAISALABAD FOR THE PRODUCT EVALUATION OF LED PANEL LIGHT

FOLLOWING ATTENDED

01. Head of Cardiology,

02. A.M.S (Purchase),

03. D.M.S (Purchase),

04. Electronic Equipment Care Taker,

05. Pharmacist,

06. Sub. Engineer (Electrical),

Chairman

Member

Member

Member

Member

Member

The committee was intimated that tenders were invited through PPRA website on dated 08/05/2021 for the purchase of LED panel light.

r.# Award	# Name of Item	Brand/Manufacturer	Contractor/Firm
1 1.0	LED PANEL LIGHT WITH BUILTIN DRIVER COMPLETE SIZE 2X2 FEET, INPUT VOLTAGE 230, 50 Hz, POWER FACTOR SHOULD BE 0.9 OR ABOVE. LUX MINIMUM 300 OR ABOVE AT DISTANCE OF 06 FT COLOR DAY LIGH WITH MINIMUM ONE YEARS REPLACEMENT WARRANTY.	T.N.A Less Lux as per tender requirement Opple China T.A PHILIPS	M/s Zahid Khan & Co. I CACHE
		T.N.A sample not provided Sparkled China	M/s Abdullah Traders

Bid of M/s OSAKA has been rejected due to Technical offer not attached and bidding documents not in proper form and bid of M/s American Electronics also rejected due to firm has no past experience

The committee unanimously technically approved / technically not approved the brands of the above mentioned firms in each items.

Sub. Engineer (Electrical), F.I.C, Faisalabad.

Pharmacist, F.I.C, Faisalabad

Electronic Equipment Care Taker,

F.I.C, Faisalabad

D.M.S (Purchase), F.I.C, Faisalabad A.M.S (Purchase), F.I.C, Faisalabad Head of Cardiology, F.I.C. Faisalabad